

(BG)



Titon

894 The Crescent
Colchester Business Park
Colchester
Essex
CO4 9YQ

HRV20 HE Q + BC

TP653BC/LH

SEC A + ()

SEC A + ()

SEC E ()

85%

640m³/h

115.40W

60dB

1.2444m³/s

50Pa

SPI 0.2576W/(m³/h)

0.65 *

5%

5%

SEC	kWh/(m².a)	-80.6	-42.0	-17.3
AEC	kWh/a	7.2	1.8	1.4
AHS	kWh	89.8	45.9	20.8

Aurastat/Auramode

/

www.titon.com

* 0-10V